



Location	Reserve Christina Cr - Peace St
Area/length	3km
Category	maintain firebreaks
Instructions	Fire access track for Fire Access with 3m trafficable width and low fuel if 0.5m either side and vertical clearance of 5m. Where adjoining Houses in NW near Kerr Close and SE near Federal St low fuel to area to be 3m wide each side of track to form a 6 to 10m wide low fuel buffer in total (including track 4m and low fuel areas)

CHECKLIST	ACTION
Environmental Sensitive Areas (ESA's)	
Public Drinking Water Source	
Threatened & Declared Rare Flora (DRF)	
Rare and Endangered Fauna Habitat	
Carnaby Cockatoo Roosts	
State Heritage sites or Aboriginal Heritage Sites	
wetlands	
Threatened Ecological Communities/PEC's	
Migratory Birds Species protected areas	
Environmental Considerations	
Dieback / disease risk area (<i>Phytophthora cinnamomi</i>)	yes dieback map needed
Nature Reserves	y
Habitat connectivity and vegetation notes	
Waterways - will planned works impact on water courses, wetlands, inlet, riparian zone?	
Weeds (WONS, declared, invasive)	yes inc. watsonia, golden wattle, asparagus fern
Acid Sulphate Soil risk areas	
Local Checks	
Traffic management needed	
Utilities check	Contractor to do
other	